





# Bloque de distribución 500A, UKK500A




5012.011




## Características

- Bloque de distribución modular, monopolar, cable y busbar, 500A 600V, entrada 4x 15.5 x 0.8 x 8 x 24 x 1 salida 2x 1-14AWG/5x 14-4AWG/4x 6-14 AWG
- Dimensiones: 96 mm (alto), 49 mm (ancho), 50 mm (profundidad)
  - Voltaje de operación: 690 V (IEC), 600 V (UL)
  - Clase de protección: IP20
  - Corriente de operación: 250 A (IEC60947-7-1), 255 A (UL/CSA)
  - Cables entrada  / salida  :

## Contáctanos

-  (55)79477137
-  cotizaciones@spsinergia.com
-  Maria Luisa Martínez 139,  
Morelia Michoacán. CP 58150

Directly with TH flexible busbar connection



TH flexible busbar

	4 x 15.5 x 0.8
	6 x 15.5 x 0.8
	2 x 20 x 1
	3 x 20 x 1
	4 x 20 x 1
	5 x 20 x 1
	6 x 20 x 1
	2 x 24 x 1
	3 x 24 x 1
	4 x 24 x 1
	5 x 24 x 1
	6 x 24 x 1
	8 x 24 x 1

Metric system	mm <sup>2</sup>	mm <sup>2</sup>		(N.m)
	4x15.5x0.8 ...8x24x1	4x15.5x0.8 ...8x24x1		2.5
	6...35	6...25	x2	4.0
	2.5...16	2.5...16	x5	2.7
	2.5...10	2.5...10	x4	2.5

U.S. Regulations	AMG		Torque
	4x15.5x0.8 ...8x24x1		17.5
	14...1	x2	35
	14...4	x5	24
	14...6	x4	17.5



# C E R T I F I C A T E

## ATTESTATION CERTIFICATE OF ELECTROMAGNETIC COMPATIBILITY AND LOW VOLTAGE DIRECTIVES

Technical file of the company mentioned below has been observed and audit has been completed successfully.

2014/30/EU Electromagnetic Compatibility Directive and  
2014/35/EU Low Voltage Directives have been taken as references for these processes

Company Name : **Shanghai Leipold Electric Co., Ltd.**

Company Address : No.1569 Siyi Road, Jiading, Shanghai, China

Related Directives and Annex : **2014/35/EU Low Voltage Directive**  
**2014/30/EU Electromagnetic Compatibility Directive**

Related Standards : **EN 60947-1:2007/A2:2014;EN 60947-7-1:2009**

Product Name : **Power Distribution Blocks**

Report No and Date : KOSE2018052932;26.05.2018

Product Brand/Model/Type : UK207,UK407,UK411,UK412,UK415,UKK-80A,  
UKK-125A,UKK-160A,UKK-250A,UKK-400A,UKK-500A,  
UKK600A,JUKH125,JUKH250,UKK6/47,UKK6/47LE,  
UKK6G/158,UKK6G-100,UKK6G-250,UKK6G-400,UKK6G-600,  
UKK6N-100,UKK6N-250,UKK6N-400,UKK6N-600,UKK6NB-100,  
UKK6NB-250,UKK6NB-400,UKK6NB-600

Certificate Number : **M.2018.201.N5030**

Initial Assessment Date : 14.06.2018

Registration Date : 15.06.2018

Reissue Date/No : -

**Expiry Date : 14.06.2023**

The validity of the certificate can be checked through [www.udem.com.tr](http://www.udem.com.tr). The CE mark shown on the right can only be used under the responsibility of the manufacturer with the completion of EC Declaration of Conformity for all the relevant Directives. This certificate remains the property of UDEM International Certification Auditing Training Centre Industry and Trade Inc. Co. to whom it must be returned upon request. The above named firm must keep a copy of this certificate for 15 years from the registration of certificate. This certificate only covers the product(s) stated above and UDEM must be noticed in case of any changes on the product(s)

**Address:** Mutlukent Mahallesi 2073 Sokak (Eski 93 Sokak) No:10 Çankaya – Ankara – TURKEY

**Phone:** +90 0312 443 03 90 **Fax:** +90 0312 443 03 76

**E-mail:** [info@udemltd.com.tr](mailto:info@udemltd.com.tr) [www.udem.com.tr](http://www.udem.com.tr)

  
UDEM International Certification  
Auditing Training Centre Industry  
and Trade Inc. Co.

