

Transformador de control 250VA 380-220V JBK5-250

4011.005



Características

- Dimensiones: 104 mm (alto), 96 mm (ancho), 100mm (profundidad)
- Voltaje de operación: 380V
- Potencia aparente: 250VA
- Serie: JBK5




Contáctanos

-  (55)79477137
-  cotizaciones@spsinergia.com
-  Maria Luisa Martínez 139,
Morelia Michoacán. CP 58150


Technical data

Model	Order number	B max	D max	E max	Hole distance		Hole diameter K	F max	Remarks
					A	C			
JBKS-40, 63	4011.001/2	78	72	90	56±0.15	46±0.125	4.6	1.5	
JBKS-100	4011.003	84	75	96	64±0.15	62±0.15	4.6	1.5	
JBKS-160	4011.004	96	92	106	84±0.175	73.5±0.15	5.5	1.5	
JBKS-250	4011.005	96	100	104	84±0.175	85±0.175	5.8	1.5	
JBKS-400	4011.006	120	100	122	90±0.175	85±0.175	5.8	2	
JBKS-500		120	110	122	90±0.175	96±0.175	5.8	2	
JBKS-630	4011.007	150	110	140	122±0.2	90±0.175	7	2	
JBKS-800	4011.008	150	128	142	122±0.2	105±0.2	7	2	
JBKS-1000	4011.009*	150	190	142	126±0.2	152±0.2	7	3	Horizontal
JBKS-1000	4011.009*	168	125	155	138±0.2	105±0.2	9	2	Vertical
JBKS-1600	4011.010*	170	225	153	140±0.2	176±0.2	7	3	Horizontal
JBKS-1600	4011.010*	168	138	155	138±0.2	116±0.2	9	2	Vertical
JBKS-2500	4011.011	194	250	170	170±0.2	200±0.23	7	4	Horizontal
JBKS-2500	4011.011	228	200	230	190±1.0	122±1.0	10	4	Vertical
JBKS-3000	4011.012	194	250	190	170±0.2	200±0.23	7	4	Horizontal
JBKS-3000	4011.012	228	210	230	190±1.0	132±1.0	10	4	Vertical
JBKS-4000	4011.013	194	250	200	170±0.2	200±0.23	7	4	Horizontal
JBKS-4000	4011.013	228	240	230	190±1.0	152±1.0	10	4	Vertical
JBKS-5000	4011.014	220	286	215	208±0.5	240±0.5	9	4	Horizontal
JBKS-5000	4011.014	240	225	240	200±1.0	152±1.0	10	4	Vertical
JBKS-6000	4011.015	220	286	215	208±0.5	240±0.5	9	4	Horizontal
JBKS-6000	4011.015	240	240	240	200±1.0	162±1.0	10	4	Vertical
JBKS-7000	4011.016*	220	286	250	208±0.5	240±0.5	9	4	Horizontal
JBKS-7000	4011.016*	240	240	260	200±0.5	165±0.5	12	4	Vertical
JBKS-8000	4011.017	270	310	320	225±0.5	205±0.5	12	4	Vertical
JBKS-10000	4011.018	270	310	320	225±0.5	205±0.5	12	4	Vertical
JBKS-15KVA	4011.019	330	270	480	290	150	14	5	Vertical
JBKS-20KVA	4011.020	330	300	480	290	180	14	5	Vertical
JBKS-30KVA	4011.021	330	320	480	290	200	14	5	Vertical
JBKS-40KVA	4011.022	330	320	480	290	300	14	5	Vertical
JBKS-50KVA	4011.023	440	320	600	380	210	14	7	Vertical
JBKS-60KVA	4011.024	440	320	600	380	210	14	7	Vertical




JBKS-40-800



JBKS-1000-1600 Vertical



JBKS-1000-2500





ISET S.r.l.

Sede Legale e Uffici
Via Donatori di sangue, 9 - 46024 Moglia (MN)
Tel. e fax +39 (0)376 598963
iset@iset-italia.com www.iset-italia.eu

Cap. soc. i.v. € 10.200,00
Cod. Fisc. e P.IVA 02 332 750 369
Reg. Imprese 02 332 750 369
REA MN 0221098

CERTIFICATE OF COMPLIANCE

Certificado de Conformidade - Сертификат соответствия - Konformitätserklärung

1) APPLICANT:

Shanghai Leipold Electric Co., Ltd.
No.1569 Siyi Road, Jiading, Shanghai, China.

2) CERTIFICATE NO.:

IT1347LP17011804

TEST REPORT(S) NO.:

SCC(17)-00812-1-10-LVD
SCC(17)-00812-1-10-EMC
China CEPREI (Sichuan) Laboratory

3) WITH REFERENCE TO EC DIRECTIVE APPLIED:

Low Voltage Directive 2014/35/EU
Electromagnetic Compatibility 2014/30/EU

HARMONIZED STANDARDS APPLIED:

EN 61558-1:2005/A1:2009
EN 61558-2-4:2009, EN 61000-6-1:2007,
EN 61000-6-3:2007+A1:2011+AC: 2012
EN 61000-3-2:2014, EN 61000-3-3:2013

4) CERTIFICATION ISET MARK:



5) PRODUCT CHARACTERISTICS: Control Transformer

MODEL(S): JBK3, JBK5, JBK6, JBK7, DBK, DZD, JSZ

REMARK: The verification has been carried out on a voluntary basis. We attest that a TCF is in place. The product(s) satisfies the requirements of the Certification Mark of ISET, in reference to the above list standard(s). The above compliance mark can be fixed on the product(s) according to the ISET regulation about its release. This verification doesn't imply assessment of the production and the product(s).



Notice of the CE marking: The label of the CE marking: Not less than 5mm height. Before putting the product(s) into market, CE marking and EC declaration are duties of the manufacturer. The manufacturer is responsible to start the CE marking certification procedure and to perform the activities according to all the relative directive(s).

6) DATE OF ISSUE: 17/01/2018

DATE OF EXPIRE: 16/01/2023

CERTIFICATION MANAGER:

