



# Transformador de control 400VA 380-220V JBK5-400

4011.006



## Características

Transformador de control de maquina, IP20, voltaje de entrada 380v, voltaje de salida 220V

- Dimensiones: 122 mm (alto), 120 mm (ancho), 100mm (profundidad)
- Voltaje de operación: 380V
- Potencia aparente: 400VA
- Serie: JBK5




## Contáctanos

- (55)79477137
- cotizaciones@spsinergia.com
- Maria Luisa Martínez 139,  
Morelia Michoacán. CP 58150


**Technical data**

Model	Order number	B max	D max	E max	Hole distance		Hole diameter K	F max	Remarks
					A	C			
JBK5-40, 63	4011.001/2	78	72	90	56±0.15	46±0.125	4,6	1,5	
JBK5-100	4011.003	84	75	96	64±0.15	62±0.15	4,6	1,5	
JBK5-160	4011.004	96	92	105	84±0.175	73.5±0.15	5,5	1,5	
JBK5-250	4011.005	96	100	104	84±0.175	85±0.175	5,8	1,5	
JBK5-400	4011.006	120	100	122	90±0.175	85±0.175	5,8	2	
JBK5-500		120	110	122	90±0.175	96±0.175	5,8	2	
JBK5-630	4011.007	150	110	140	122±0.2	90±0.175	7	2	
JBK5-800	4011.008	150	128	142	122±0.2	105±0.2	7	2	
JBK5-1000	4011.009*	150	190	142	126±0.2	152±0.2	7	3	Horizontal
JBK5-1000	4011.009*	168	125	155	138±0.2	105±0.2	9	2	Vertical
JBK5-1600	4011.010*	170	225	153	140±0.2	176±0.2	7	3	Horizontal
JBK5-1600	4011.010*	168	138	155	138±0.2	116±0.2	9	2	Vertical
JBK5-2500	4011.011	194	250	170	170±0.2	200±0.23	7	4	Horizontal




JBK5-40-800



JBK5-1000-1600 Vertical



JBK5-1000-2500







**ISET S.r.l.**

Sede Legale e Uffici  
Via Donatori di sangue, 9 - 46024 Moglia (MN)  
Tel. e fax +39 (0)376 598963  
iset@iset-italia.com [www.iset-italia.eu](http://www.iset-italia.eu)

Cap. soc. i.v. € 10.200,00  
Cod. Fisc. e P.IVA 02 332 750 369  
Reg. Imprese 02 332 750 369  
REA MN 0221098

## CERTIFICATE OF COMPLIANCE

Certificado de Conformidade - Сертификат соответствия - Konformitätserklärung

**1) APPLICANT:**

Shanghai Leipold Electric Co., Ltd.  
No.1569 Siyi Road, Jiading, Shanghai, China.

**2) CERTIFICATE NO.:**

IT1347LP17011804

**TEST REPORT(S) NO.:**

SCC(17)-00812-1-10-LVD  
SCC(17)-00812-1-10-EMC  
China CEPREI (Sichuan) Laboratory

**3) WITH REFERENCE TO EC DIRECTIVE APPLIED:**

Low Voltage Directive 2014/35/EU  
Electromagnetic Compatibility 2014/30/EU

**HARMONIZED STANDARDS APPLIED:**

EN 61558-1:2005/A1:2009  
EN 61558-2-4:2009, EN 61000-6-1:2007,  
EN 61000-6-3:2007+A1:2011+AC: 2012  
EN 61000-3-2:2014, EN 61000-3-3:2013

**4) CERTIFICATION ISET MARK:**



**5) PRODUCT CHARACTERISTICS:** Control Transformer

**MODEL(S):** JBK3, JBK5, JBK6, JBK7, DBK, DZD, JSZ

**REMARK:** The verification has been carried out on a voluntary basis. We attest that a TCF is in place. The product(s) satisfies the requirements of the Certification Mark of ISET, in reference to the above list standard(s). The above compliance mark can be fixed on the product(s) according to the ISET regulation about its release. This verification doesn't imply assessment of the production and the product(s).



**Notice of the CE marking:** The label of the CE marking: Not less than 5mm height. Before putting the product(s) into market, CE marking and EC declaration are duties of the manufacturer. The manufacturer is responsible to start the CE marking certification procedure and to perform the activities according to all the relative directive(s).

**6) DATE OF ISSUE:** 17/01/2018

**DATE OF EXPIRE:** 16/01/2023

**CERTIFICATION MANAGER:**

